Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM019

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: RASMASSEM CHRIS	Phone #
Mailing Address: 1642 HORNET TRAIL	
City: NEKOOSA	State: WI / Zip Code: 54457

County	Co. Permit #	Notification #	Completed
Adams		10149419501	02-26-2026

Well Constructor (Business Name): ROTH WELL DRILLING	Lic. #: 5857
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: PO BOX 532 NEKOOSA WI 54457	
Approval Date (mm-dd-yyyy)	

Hicap Permanent Well #	Common Well #	Specific Capacity: 6.7

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of ROME

Fire # (if avail.)

Street Address or Road Name and Number: 1642 HORNET TRAIL

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 44.1631 °N -89.8803 °W
Method Code: GPS008

SE	NE	Section	Township	Range
or Govt Lot #		34	20 N	5 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD WELL FAILED

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	79

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	52
		X		X-SAND & CLAY	52	67
	N	S		N-FINE S-SAND	67	72
	A	Y		A-COARSE Y-SAND & GRAVEL	72	79

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	A 53 B .280 SAWHILL WELDED	Surface	76
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	TELE JOHNSON SS 12 SLOT	76	79

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	76	2 S

9. Static Water Level
42 ft. below ground surface

10. Pump Test
Pumping level 45 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KR	4495	03-13-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MG	3740	03-13-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 03-05-2026 Updated On: 04-09-2026 Review Status: APPROVED