

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM026		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SCANDARIATO TIM						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 34306 51ST ST						Town of WHEATLAND											
City BURLINGTON						State WI		Zip Code 53105									
County Kenosha		Co. Permit #		Notification # 10146238401		Completed 02-13-2026		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) GOHLKE WELL DRILLING LLC				Lic. # 6642		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.5929 °N -88.2274 °W				Method Code GPS008			
Address 5338 STATE RD 50 BURLINGTON WI 53105				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 34 2 N 19 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
9		Surface		68		<u>Yes</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				Y F F-FILL Surface 2 Y C Y-YELLOW C-CLAY 2 17 G C G-GRAY C-CLAY 17 62 Y Y-SAND & GRAVEL 62 68							
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 35 ft. below ground surface				11. Well Is 12 in. above grade			
5		NEW PVC CERTAINTED 1120 SDR 21 PWD2241				Surface		63		10. Pump Test Pumping level 60 ft. below surface Pumping at 12 GP M for 1 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		5'X5" PVC .10 SLOT TITAN HYFLOW				63		68									
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED												12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
GROUT WELL DF				Surface		63		7									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
TLS												6643		03-05-2026			
Drill Rig Operator												Lic or Reg #		Date Signed			
JRR												9534		03-05-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		100

Comment:

Created On: 03-05-2026

Updated On: 04-03-2026

Review Status: APPROVED