Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM026

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCANDARIATO TIM			Phone #
Mailing Address: 34306 51ST ST			
City: BURLINGTON	State: WI	Zip Code: 53105	
County: Kenosha	Co. Permit #:	Notification #: 10146238401	Completed: 02-13-2026

Well Constructor (Business Name): GOHLKE WELL DRILLING LLC	Lic. #: 6642	Facility ID # (Public Wells):	
Address: 5338 STATE RD 50 BURLINGTON WI 53105		Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

1. Well Location

Town of WHEATLAND

Fire # (if avail.):

Street Address or Road Name and Number: 34306 51ST ST

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 42.5929 °N -88.2274 °W				Method Code: GPS008
SE NE or Govt Lot #:	Section: 34	Township: 2 N	Range: 19 E	

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	68

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		F		F-FILL	Surface	2
Y		C		Y-YELLOW C-CLAY	2	17
G		C		G-GRAY C-CLAY	17	62
		Y		Y-SAND & GRAVEL	62	68

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NEW PVC CERTAINTEED 1120 SDR 21 PWD2241	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	5'X5" PVC .10 SLOT TITAN HYFLOW	63	68

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GROUT WELL DF	Surface	63	7

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLS	6643	03-05-2026
Drill Rig Operator	Lic or Reg #	Date Signed
JRR	9534	03-05-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		100

Comment:

Created On: 03-05-2026 Updated On: 04-03-2026 Review Status: APPROVED