Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM027

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CORLI TREVOR	Phone #
Mailing Address: 28421 107TH ST	
City: TREVOR	State: WI — Zip Code: 53179
County: Kenosha	Co. Permit #: — Notification #: 10155416201 — Completed: 02-26-2026
Well Constructor (Business Name): GOHLKE WELL DRILLING LLC	Lic. #: 6642 — Facility ID # (Public Wells):
Address: 5338 STATE RD 50 BURLINGTON WI 53105	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.2

1. Well Location

Village of SALEM LAKES

Fire # (if avail.):

Street Address or Road Name and Number: 28421 107TH ST

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 42.5199 °N -88.1533 °W — Method Code: GPS008

SW NE or Govt Lot #: — Section: 29 — Township: 1 N — Range: 20 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: POINT WELL NOT IN CODE

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	69

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K		I	F	K-BLACK I-SOIL-ORGANIC F-W/FILL	Surface	3
Y		C		Y-YELLOW C-CLAY	3	18
G		C		G-GRAY C-CLAY	18	62
		Y		Y-SAND & GRAVEL	62	69

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NEW PVC CERTAINTEED 1120 SDR 21 PWD2241	Surface	64
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	5'X5" PVC .10 SLOT TITAN HYFLOW	64	69

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GROUT WELL DF	Surface	64	7

9. Static Water Level

10 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

GOHLKE DONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLS	6643	03-05-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JRR	9534	03-05-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		200

Comment:

Created On: 03-05-2026 Updated On: 04-03-2026 Review Status: APPROVED