

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM027		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner CORLI TREVOR					Phone #		1. Well Location				Fire # (if avail.)				
Mailing Address 28421 107TH ST							Village of SALEM LAKES								
City TREVOR					State WI		Zip Code 53179		Street Address or Road Name and Number 28421 107TH ST						
County Kenosha		Co. Permit #		Notification # 10155416201		Completed 02-26-2026		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) GOHLKE WELL DRILLING LLC				Lic. # 6642		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.5199 °N -88.1533 °W			Method Code GPS008		
Address 5338 STATE RD 50 BURLINGTON WI 53105				Well Plan Approval #				SW NE		Section 29		Township 1 N		Range 20 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #			Common Well #			Specific Capacity 1.2			2. Well Type Replacement						
									of previous unique well # constructed in						
									Reason for replaced or reconstructed well ? POINT WELL NOT IN CODE						
									Construction Type Drilled						
3. Well serves 1 # of HOME												Hicap Well ? No			
Private, potable												Hicap Property ? No			
Heat Exchange ____ # of drillholes												Hicap Potable ? No			
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
9		Surface		69		<u>Yes</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ____ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ____ in. dia <u>No</u> Removed? ____ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
K I F				K-BLACK I-SOIL-ORGANIC F-W/FILL				Surface		3					
Y C				Y-YELLOW C-CLAY				3		18					
G C				G-GRAY C-CLAY				18		62					
				Y-SAND & GRAVEL				62		69					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
5		NEW PVC CERTAINTED 1120 SDR 21 PWD2241				Surface		64							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
5		5'X5" PVC .10 SLOT TITAN HYFLOW				64		69							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GROUT WELL DF				Surface		64		7							
9. Static Water Level															
10 ft. below ground surface															
10. Pump Test															
Pumping level 20 ft. below surface															
Pumping at 12 GP M for 1 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? Yes															
GOHLKE DONE															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
TLS				6643		03-05-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									
JRR				9534		03-05-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		200

Comment:

Created On: 03-05-2026

Updated On: 04-03-2026

Review Status: APPROVED