Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM028

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	LAVERN KERTSCHER
Phone #	
Mailing Address	319 WINDELL AVE
City	CAMPBELLSPORT
State	WI
Zip Code	53010

County	Co. Permit #	Notification #	Completed
Forest	1	10146584702	02-25-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
NEHLS & WEBSTER WELL DRILLING	6076	

Address 1901 APACHE LN
RHINELANDER WI 54501

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.8

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of HILES

Fire # (if avail.) 7788

Street Address or Road Name and Number
BALD EAGLE LANE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.6608 °N	-88.98362 °W			SCR002

SW	NW	Section	Township	Range
or Govt Lot #		27	37 N	12 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	25

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	G	Y-SAND & GRAVEL G-W/GRAVEL/STONES	Surface	25

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	MARIUCCI PE 18.97 A53	Surface	25
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	15	1 S

9. Static Water Level
8 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
PW	156	04-27-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		30

Comment:

Created On: 03-05-2026 Updated On: 05-22-2026 Review Status: APPROVED