Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM045

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CHLEBOWSKI MIKE	Phone #
Mailing Address: N7720 STRASSER LN	
City: DEERBROOK	State: WI — Zip Code: 54424
County: Langlade	Co. Permit #: — Notification #: 10162657101 — Completed: 03-05-2026
Well Constructor (Business Name): JELINEK WELL DRILLING INC	Lic. #: 6041 — Facility ID # (Public Wells):
Address: 3480 HWY N, RHINELANDER WI 54501	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1

1. Well Location

Town of UPHAM	Fire # (if avail.): N7720
Street Address or Road Name and Number: STRASSER LN	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.308 °N -89.1877 °W	Method Code: GPS008
SW SE or Govt Lot #:	Section: 25 — Township: 33 N — Range: 10 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: FAILING POINT

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	120

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	Z		T-TAN/BROWN S-SOFT/LOOSE Z-CLAY & GRAVEL	Surface	15
T	H	Z		T-TAN/BROWN H-HARD/FIRM Z-CLAY & GRAVEL	15	105
G	A	Y		G-GRAY A-COARSE Y-SAND & GRAVEL	105	116
T	A	Y		T-TAN/BROWN A-COARSE Y-SAND & GRAVEL	116	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B 18.97 #/FT WELDED	Surface	117
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	JOHNSON 3'12 SLOT SS	117	120

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	20	2 S

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
CG	8207	03-05-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CG	8207	03-05-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		60	POWTS dispersal component (soil absorption unit or mound)		65

Comment:

Created On: 03-05-2026 Updated On: 10-15-2026 Review Status: APPROVED