

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM046		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner FORTNER, DEREK				Phone # (906)221-2658		1. Well Location				Fire # (if avail.)	
Mailing Address 924 TURNER ST.						Town of FLORENCE				839	
City KINGSFORD				State MI Zip Code 49802		Street Address or Road Name and Number 839 N. MENOMINEE SHORES RD					
County Florence		Co. Permit #		Notification # 10128680101		Completed 01-12-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) MORIN, DOUGLAS J				Lic. # 6311		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.84954 °N -88.10063 °W		Method Code GPS008	
Address MORIN AND JOHNSON WELL DRLG & PUMP 670 COOLIDGE AVE NIAGARA WI 54151				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 15 39 N 19 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 5		Reason for replaced or reconstructed well ?			
3. Well serves 1 # of HOME				Hicap Well ? No		Private,potable Drillhole		Hicap Property ? No		Construction Type Drilled	
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
6		Surface		44		No Rotary - Mud Circulation		No		T H G Z T-TAN/BROWN H-HARD/FIRM G-GRAVEL/STONES Z-W/COBBLES/BOULDERS	
						No Rotary - Air		No		T E S S T-TAN/BROWN E-CLEAN S-SAND S-SANDY	
						No Rotary - Air & Foam		No			
						No Drill-Through Casing Hammer					
						No Reverse Rotary					
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is	
6		ASTM A53B 18.97 LB/FT WELDED NUCOR				Surface		41		21 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes	
6		SS TELESCOPING #15				41		44		Disinfected ? Yes	
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Capped ? Yes	
GRANULAR BENTONITE				Surface		41		2 S		Filled & Sealed Well(s) as needed? No	
9. Static Water Level											
18 ft. below ground surface											
10. Pump Test											
Pumping level 24 ft. below surface											
Pumping at 30 GP M for 1 Hrs.											
Pumping Method ? Other											
12. Notified Owner of need to fill & seal ? No											
13. Constructor / Supervisory Driller											
DJM				Lic # 6311		Date Signed 03-05-2026					
Drill Rig Operator				Lic or Reg #		Date Signed					
DJM				6311		03-05-2026					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	60	POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	60
			POWTS dispersal component (soil absorption unit or mound)	>	70

Comment:

Created On: 03-05-2026

Updated On: 04-03-2026

Review Status: APPROVED