Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM046

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FORTNER, DEREK	Phone #: (906)221-2658
Mailing Address: 924 TURNER ST.	
City: KINGSFORD	State: MI — Zip Code: 49802
County: Florence	Co. Permit #:
Notification #: 10128680101	Completed: 01-12-2026
Well Constructor (Business Name): MORIN, DOUGLAS J	Lic. #: 6311
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: MORIN AND JOHNSON WELL DRLG & PUMP 670 COOLIDGE AVE NIAGARA WI 54151	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 5	

1. Well Location

Town of FLORENCE	Fire # (if avail.): 839
Street Address or Road Name and Number: 839 N. MENOMINEE SHORES RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.84954 °N -88.10063 °W	Method Code: GPS008
SE SE or Govt Lot #:	Section: 15 — Township: 39 N — Range: 19 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	44

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	H	G	Z	T-TAN/BROWN H-HARD/FIRM G-GRAVEL/STONES Z-W/COBBLES/BOULDERS	Surface	15
T	E	S	S	T-TAN/BROWN E-CLEAN S-SAND S-SANDY	15	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B 18.97 LB/FT WELDED NUCOR	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SS TELESCOPING #15	41	44

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	41	2 S

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 24 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ? Other

11. Well Is

21 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJM	6311	03-05-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DJM	6311	03-05-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	60	POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	60
			POWTS dispersal component (soil absorption unit or mound)	>	70

Comment:

Created On: 03-05-2026 Updated On: 04-03-2026 Review Status: APPROVED