Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM062

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DIEKVOSS, TAL			Phone #
Mailing Address: 3235 N INTERLAKEN DR			
City: OCONOMOWOC	State: WI	Zip Code: 53066	

County	Co. Permit #	Notification #	Completed
Waukesha		10157366501	03-03-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
D & D WELL & PUMPS LLC	7181	

Address: N6331 COUNTY F
OCONOMOWOC WI 53066

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		30

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Village of SUMMIT

Fire # (if avail.)

Street Address or Road Name and Number
3235 N INTERLAKEN

Subdivision Name	Lot #	Block #
THE MEADOWS OF SUMMIT	7	

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.07864	°N	-88.43938	°W	GPS008

SW SW or Govt Lot #	Section	Township	Range
	12	7 N	17 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	41
5	41	44

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97#, A53-B, NUCOR & WELDED	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS TELE 35 SLOT	41	44

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level
24 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 30 GP M for 2 Hrs.
Pumping Method ? Other

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJ	5694	03-08-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		150	Sewer - Building Sanitary		13

Comment:

Created On: 03-08-2026 Updated On: 10-15-2026 Review Status: APPROVED