

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM062		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner DIEKVOSS, TAL						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 3235 N INTERLAKEN DR						Village of SUMMIT									
City OCONOMOWOC						State WI		Zip Code 53066				Street Address or Road Name and Number 3235 N INTERLAKEN			
County Waukesha		Co. Permit #		Notification # 10157366501		Completed 03-03-2026		Subdivision Name THE MEADOWS OF SUMMIT				Lot # 7		Block #	
Well Constructor (Business Name) D & D WELL & PUMPS LLC				Lic. # 7181		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.07864 °N -88.43938 °W				Method Code GPS008	
Address N6331 COUNTY F OCONOMOWOC WI 53066				Well Plan Approval #		SW SW		Section 12		Township 7 N		Range 17 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type New Well				of previous unique well # constructed in					
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?									
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ? No											
Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		41		No Rotary - Mud Circulation				No					
5		41		44		No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						Yes Cable-tool Bit 6in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
		Y						Y-SAND & GRAVEL		Surface 44					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level					
6		STEEL, 18.97#, A53-B, NUCOR & WELDED				Surface		41		24 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test					
5		SS TELE 35 SLOT				41		44		Pumping level 25 ft. below surface					
										Pumping at 30 GP M for 2 Hrs.					
										Pumping Method ? Other					
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		11. Well Is					
GRANULAR BENTONITE				Surface						18 in. above grade					
Filled & Sealed Well(s) as needed? No															
12. Notified Owner of need to fill & seal ? No															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
DJ				5694				03-08-2026							
Drill Rig Operator				Lic or Reg #				Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		150	Sewer - Building Sanitary		13

Comment:

Created On: 03-08-2026

Updated On: 04-06-2026

Review Status: APPROVED