

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM076		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner SCHANTZ, DONULUS					Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address 1142 STATE ROAD 13							Town of BIG FLATS				1142		
City FRIENDSHIP					State WI		Zip Code 53934				Street Address or Road Name and Number STATE ROAD 13		
County Adams		Co. Permit #		Notification # 10167402101		Completed 04-16-2026		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) FARAGO, TERRY				Lic. # 41		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.09157 °N -89.80473 °W			
Address N6079 8TH AVE PLAINFIELD WI 54966-9757				Well Plan Approval # Approval Date (mm-dd-yyyy)		SW NE		Section 29		Township 19 N		Range 6 E	
						or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type New Well			
Hicap serves 1 # of HOME				Hicap Well ? No		of previous unique well #				constructed in			
Private, potable				Hicap Property ? No		Reason for replaced or reconstructed well ?							
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		96									
						No Rotary - Mud Circulation				No			
						No Rotary - Air				No			
						No Rotary - Air & Foam				No			
						Yes Drill-Through Casing Hammer							
						No Reverse Rotary							
						No Cable-tool Bit ___ in. dia...				No			
						No Dual Rotary				No			
						No Temp. Outer Casing ___ in. dia							
						No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S		S-SAND				Surface		38					
X		X-SAND & CLAY				38		41					
C		C-CLAY				41		60					
Y		Y-SAND & GRAVEL				60		96					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		IPSCO A53 6.625 X.280 WALL WELDED TOGETHER WEIGHT 1,745.24				Surface		92					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
6		10 SLOT SS				82		96					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
BENT ALONG CASING				Surface									
9. Static Water Level													
35 ft. below ground surface													
10. Pump Test													
Pumping level 35 ft. below surface													
Pumping at 20 GP M for 1 Hrs.													
Pumping Method ? Test Pump													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
TF				41				04-27-2026					
Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 03-09-2026

Updated On: 05-22-2026

Review Status: APPROVED