Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM079

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	FLEISCHMAN, DENNIS
Phone #	
Mailing Address	150987 GOLDENROD RD
City	WAUSAU
State	WI
Zip Code	54401
County	Vilas
Co. Permit #	
Notification #	10148159901
Completed	02-17-2026
Well Constructor (Business Name)	D&M WATERWORKS LLC
Lic. #	9148
Facility ID # (Public Wells)	
Address	DBA/RICHARDSON WELL DRLG 10632 STATE HWY 70 WEST MINOCQUA WI 54548
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.6

1. Well Location

Fire # (if avail.)	1046
Town of LAC DU FLAMBEAU	
Street Address or Road Name and Number	PEACH LN
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	45.8997 °N -89.8305 °W
Method Code	GPS008
SE SW or Govt Lot #	
Section	35
Township	40 N
Range	5 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	58

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	45
	A	Y		A-COARSE Y-SAND & GRAVEL	45	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ASTM, A53 WELD 19.97LBS; WHEATLAND USA	Surface	55
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	ALLOY SS 10 SLOT	55	58

9. Static Water Level

3 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TF	8520	02-17-2026
Drill Rig Operator	Lic or Reg #	Date Signed
CM	8443	02-17-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: SEPTIC NOT IN YET

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	03/09/2026	NOT HOOKED UP YET; ELECTRIC & PUMP NOT IN YET

Created On: 03-09-2026 Updated On: 10-15-2026 Review Status: APPROVED