

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM079		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner FLEISCHMAN, DENNIS					Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 150987 GOLDENROD RD							Town of LAC DU FLAMBEAU				1046	
City WAUSAU					State WI		Zip Code 54401				Street Address or Road Name and Number PEACH LN	
County Vilas		Co. Permit #		Notification # 10148159901		Completed 02-17-2026		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) D&M WATERWORKS LLC				Lic. # 9148		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.8997 °N -89.8305 °W			Method Code GPS008	
Address DBA/RICHARDSON WELL DRLG 10632 STATE HWY 70 WEST MINOCQUA WI 54548				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 35 40 N 5 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #			Common Well #		Specific Capacity 0							
3. Well serves 1 # of HOME Private, potable Drillhole Heat Exchange ___ # of drillholes					Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			
6		Surface		58		No Rotary - Mud Circulation No Yes Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						
8. Geology												
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)		To (ft.)				
S			S-SAND			Surface		45				
A Y			A-COARSE Y-SAND & GRAVEL			45		58				
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)				
6		NEW BLK ASTM, A53 WELD 19.97LBS; WHEATLAND USA				Surface		55				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)				
4		ALLOY SS 10 SLOT				55		58				
7. Grout or Other Sealing Material												
Method MOUNDED												
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				
GRANULAR BENTONITE				Surface				2 S				
9. Static Water Level												
3 ft. below ground surface												
10. Pump Test												
Pumping level 20 ft. below surface Pumping at 10 GP M for 2 Hrs. Pumping Method ? Test Pump												
11. Well Is												
12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes												
12. Notified Owner of need to fill & seal ? No												
Filled & Sealed Well(s) as needed? No												
13. Constructor / Supervisory Driller				Lic #		Date Signed						
TF				8520		02-17-2026						
Drill Rig Operator				Lic or Reg #		Date Signed						
CM				8443		02-17-2026						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment: SEPTIC NOT IN YET

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	03/09/2026	NOT HOOKED UP YET; ELECTRIC & PUMP NOT IN YET

Created On: 03-09-2026

Updated On: 04-06-2026

Review Status: APPROVED