

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM080		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MARTIN, JOSEPH						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address W10738 OLD SHAWANO RD						Town of PELLA						W10738			
City SHAWANO						State WI		Zip Code 54166				Street Address or Road Name and Number OLD SHAWANO RD, SHAWANO, WI 54166			
County Shawano		Co. Permit #		Notification # 10168254601		Completed 04-22-2026		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) SHAWANO WELL DRILLING INC				Lic. # 6001		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.763 °N -88.7894 °W				Method Code GPS008	
Address W9618 ANGLE RD SHAWANO WI 54166				Well Plan Approval #		NE NW		Section 3		Township 26 N		Range 14 E		or Govt Lot #	
Hicap Permanent Well #				Common Well #		Specific Capacity 0.5				2. Well Type Replacement of previous unique well # constructed in					
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ? PT WELL NOT WORKING					
Private, potable Drillhole				Hicap Potable ? No		Construction Type Drilled									
3. Well serves 1 # of HOME															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		99		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL ASTM A53 18.97LBS/FT WHEATLAND WELDED				Surface		95							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		STAINLESS STEEL 12 SLOT WIRE WRAP				95		99							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface				1 S							
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T N S U				T-TAN/BROWN N-FINE S-SAND U-MUDDY OR MURKY				Surface		11					
R S X S				R-RED S-SOFT/LOOSE X-SAND & CLAY S-SANDY				11		74					
R X Z C				R-RED X-LENSED/STREAKED/LAYERED Z-CLAY & GRAVEL C-CLAYEY				74		94					
T M Y S				T-TAN/BROWN M-MEDIUM Y-SAND & GRAVEL S-SANDY				94		99					
9. Static Water Level															
29 ft. below ground surface															
10. Pump Test															
Pumping level 55 ft. below surface															
Pumping at 12 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
20 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
JDD				6331		04-22-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									
JL				7417		04-22-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		97	POWTS dispersal component (soil absorption unit or mound)		116

Comment:

Created On: 03-09-2026

Updated On: 05-19-2026

Review Status: APPROVED