Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM080

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MARTIN, JOSEPH	Phone #
Mailing Address: W10738 OLD SHAWANO RD	
City: SHAWANO	State: WI — Zip Code: 54166
County: Shawano	Co. Permit #: — Notification #: 10168254601 — Completed: 04-22-2026
Well Constructor (Business Name): SHAWANO WELL DRILLING INC	Lic. #: 6001 — Facility ID # (Public Wells):
Address: W9618 ANGLE RD, SHAWANO WI 54166	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location

Town of PELLA	Fire # (if avail.): W10738
Street Address or Road Name and Number: OLD SHAWANO RD, SHAWANO, WI 54166	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.763 °N -88.7894 °W	Method Code: GPS008
NE NW or Govt Lot #:	Section: 3 — Township: 26 N — Range: 14 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: PT WELL NOT WORKING

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	99

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	N	S	U	T-TAN/BROWN N-FINE S-SAND U-MUDDY OR MURKY	Surface	11
R	S	X	S	R-RED S-SOFT/LOOSE X-SAND & CLAY S-SANDY	11	74
R	X	Z	C	R-RED X-LENSED/STREAKED/LAYERED Z-CLAY & GRAVEL C-CLAYEY	74	94
T	M	Y	S	T-TAN/BROWN M-MEDIUM Y-SAND & GRAVEL S-SANDY	94	99

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL ASTM A53 18.97LBS/FT WHEATLAND WELDED	Surface	95
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL 12 SLOT WIRE WRAP	95	99

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level

29 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

20 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JDD	6331	04-22-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JL	7417	04-22-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		97	POWTS dispersal component (soil absorption unit or mound)		116

Comment:

Created On: 03-09-2026 Updated On: 05-19-2026 Review Status: APPROVED