Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM092

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HARP DEVELOPMENT	Phone #
Mailing Address: 1414 MILLA WAY	
City: BURLINGTON	State: WI — Zip Code: 53105
County: Racine	Co. Permit #: — Notification #: 10149701704 — Completed: 03-04-2026
Well Constructor (Business Name): KRIZAN, KENNETH J	Lic. #: 6519 — Facility ID # (Public Wells):
Address: 23900 W OVERSON RD UNION GROVE WI 53182-9659	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.8

1. Well Location

Town of BURLINGTON

Fire # (if avail.):

Street Address or Road Name and Number: 1414 MILLA WAY

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 42.7007 °N -88.2323 °W — Method Code: GPS008

SE	SE	Section	Township	Range
or Govt Lot #		22	3 N	19 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	81

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
X	X-SAND & CLAY	Surface	25
S	S-SAND	25	55
Y	Y-SAND & GRAVEL	55	68
L	L-LIMESTONE/DOLOMITE	68	81

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NUCORE ASTM A 53B 6.625X.280 FULL 20 WELDED	Surface	68
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

33 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	68	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KK	6519	03-09-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 03-09-2026 Updated On: 10-15-2026 Review Status: APPROVED