Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM098

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JENNUFER BORCH	Phone #
Mailing Address: 16615 LOUIS LN	
City: BROOKFIELD	State: WI Zip Code: 53005
County: Waukesha	Co. Permit #:
Notification #: 10162644501	Completed: 03-06-2026

1. Well Location

Town of BROOKFIELD

Fire # (if avail.)

Street Address or Road Name and Number: 16615 LOUIS LN

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): KRIZAN, KENNETH J	Lic. #: 6519	Facility ID # (Public Wells)	
Address: 23900 W OVERSON RD UNION GROVE WI 53182-9659		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.3	

Latitude / Longitude in Decimal Degree (DD): 43.0323 °N -88.1196 °W — Method Code: GPS008

SE	SW	Section	Township	Range
or Govt Lot #		27	7 N	20 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: PUMP STUCK IN WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	97

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y		C		Y-YELLOW C-CLAY	Surface	10
U		C		U-BLUE C-CLAY	10	40
U		Z		U-BLUE Z-CLAY & GRAVEL	40	85
		Y		Y-SAND & GRAVEL	85	92
		L		L-LIMESTONE/DOLOMITE	92	97

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NUCORE ASTM A 53B 6.625X.280 FULL 20 WELDED	Surface	97
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

22 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

16 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	97	

12. Notified Owner of need to fill & seal ? Yes

WELL WILL BE SEALED BY AQUA WELL AND PUMP

Filled & Sealed Well(s) as needed? Yes

WELL WILL BE SEALED BY AQUA WELL AND PUMP

13. Constructor / Supervisory Driller	Lic #	Date Signed
KK	6519	03-09-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 03-09-2026 Updated On: 10-15-2026 Review Status: APPROVED