Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM107

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: 458 TOMAHAWK LLC			Phone #
Mailing Address: P.O. BOX 45078			
City: MADISON	State: WI	Zip Code: 53744	
County: Adams	Co. Permit #:	Notification #: 10162618401	Completed: 03-05-2026

Well Constructor (Business Name): BERTRAM JUNEMANN WELL DRILLING INC	Lic. #: 84	Facility ID # (Public Wells):	
Address: 7117 COUNTY ROAD S RUDOLPH WI 54475		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 6	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of ROME

Fire # (if avail.)

Street Address or Road Name and Number
458 TOMAHAWK TRL

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.1881 °N	-89.8151 °W			GPS008
NW SW or Govt Lot #	Section: 20	Township: 20 N	Range: 6 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	92

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	44
		S	M	S-SAND M-SILTY	44	47
		N		N-SANDSTONE	47	92

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. A-53 .280 NTP-TRI	Surface	47
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level
41 ft. below ground surface

10. Pump Test
Pumping level 46 ft. below surface
Pumping at 30 GP M for 0.5 Hrs.
Pumping Method ? Test Pump

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJ	6733	03-23-2026
Drill Rig Operator	Lic or Reg #	Date Signed
LH	9349	03-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	55	Septic or Holding, or POWTS Tank	>	30

Comment:

Created On: 03-09-2026 Updated On: 10-15-2026 Review Status: APPROVED