

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM128		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner GARDNER-J&T PLUMBING						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 234819 STACEY CIRCLE						Town of WAUSAU						157471			
City WAUSAU						State WI		Zip Code 54403				Street Address or Road Name and Number LAND ART ROAD			
County Marathon		Co. Permit #		Notification # 10156956101		Completed 03-07-2026		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) HORNUNG, JAMES JR				Lic. # 9013		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.9814 °N -89.5842 °W				Method Code GPS008	
Address HORNUNG WELL DRLG LLC N925 CTY HWY W MERRILL WI 54452				Well Plan Approval #		NE SW		Section 20		Township 29 N		Range 8 E			
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type Replacement of previous unique well # constructed in					
3. Well serves 1 # of HOME Private, potable Nontransient Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Reason for replaced or reconstructed well ? DRILLED NEW WELL EXISTING WELL WAS NOT CODE COMPLIANT									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8 Surface 40			No Rotary - Mud Circulation No												
6 40 200			Yes Rotary - Air Yes												
			No Rotary - Air & Foam No												
			No Drill-Through Casing Hammer Reverse Rotary												
			No Cable-tool Bit ___ in. dia... No												
			No Dual Rotary No												
			No Temp. Outer Casing ___ in. dia												
			No Removed? ___ depth ft. (If NO explain on back side)												
8. Geology															
Dia. (in.) From (ft.) To (ft.)			Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)						
			C			C-CLAY			Surface 8						
			E Q			E-GREEN Q-GRANITE			8 200						
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is	
6		FEMCO 530 6.625 280 WALL WELDED USA 18.9#				Surface		40		6 ft. below ground surface				18 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes	
										Pumping level 180 ft. below surface				Disinfected ? Yes	
										Pumping at 4 GP M for 1 Hrs.				Capped ? Yes	
										Pumping Method ? Airlift					
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT GROUT				Surface		40		10 S							
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller						Lic #		Date Signed							
JH						9013		03-23-2026							
Drill Rig Operator						Lic or Reg #		Date Signed							
MH						9067		03-23-2026							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 03-10-2026

Updated On: 06-04-2026

Review Status: APPROVED