

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM138		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner HOFFMAN					Phone #			1. Well Location				Fire # (if avail.)			
Mailing Address 231930 COUNTY RD M								Town of CASSEL				224953			
City ATHENS					State WI		Zip Code 54411		Street Address or Road Name and Number				224953 CARDINAL LANE		
County Marathon		Co. Permit #		Notification # 10160303001		Completed 03-03-2026		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name)				Lic. # 9013		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code			
HORNUNG, JAMES JR								44.91082 °N -89.9236 °W				GPS008			
Address HORNUNG WELL DRLG LLC N925 CTY HWY W MERRILL WI 54452				Well Plan Approval #		SW NW Section Township Range		2. Well Type New Well							
				Approval Date (mm-dd-yyyy)		or Govt Lot # 16 28 N 5 E									
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ?									
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled									
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
8		Surface		40		<u>No</u> Rotary - Mud Circulation		<u>No</u>		Geology Codes R D Q		Type, Caving/Noncaving, Color, Hardness, etc...			
6		40		200		<u>Yes</u> Rotary - Air		<u>Yes</u>		R H Q		R-RED D-DECOMPOSED/WEATHERED Q-GRANITE			
						<u>No</u> Rotary - Air & Foam		<u>No</u>				From (ft.) To (ft.)			
						<u>No</u> Drill-Through Casing Hammer						Surface 30			
						<u>No</u> Reverse Rotary						30 200			
						<u>No</u> Cable-tool Bit ___ in. dia...		<u>No</u>							
						<u>No</u> Dual Rotary		<u>No</u>							
						<u>Yes</u> Temp. Outer Casing 10in. dia									
						<u>Yes</u> Removed? 10depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		18 ft. below ground surface		18 in. above grade			
6		FEMCO 530 6.625 280 WALL WELDED USA 18.9#				Surface		40		10. Pump Test		Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 180 ft. below surface		Disinfected ? Yes			
										Pumping at 5 GP M for 12 Hrs.		Capped ? Yes			
										Pumping Method ? Test Pump					
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?		No	
Method GROUT DISPLACEMENT (PLUG)												Filled & Sealed Well(s) as needed?		No	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
NEAT CEMENT GROUT		Surface		40		8 S									
13. Constructor / Supervisory Driller												Lic #		Date Signed	
JH												9013		03-23-2026	
Drill Rig Operator												Lic or Reg #		Date Signed	
MH												9067		03-23-2026	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	75	Septic or Holding, or POWTS Tank	=	35

Comment: HYDROFRACTURED-1GPM BEFORE, 5GPM AFTER**Created On:** 03-10-2026**Updated On:** 04-21-2026**Review Status:** APPROVED