Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM140

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WEAVER, ELTON	Phone #
Mailing Address: N2224 FRENCH RIDGE RD	
City: MERRILL	State: WI — Zip Code: 54452
County: Lincoln	Co. Permit #: — Notification #: 10155434701 — Completed: 03-04-2026

1. Well Location

Town of RUSSELL	Fire # (if avail.): N4917
Street Address or Road Name and Number: N4917 COUNTY LINE RD	
Subdivision Name: — Lot #: — Block #: —	

Well Constructor (Business Name): HORNUNG, JAMES JR	Lic. #: 9013	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 45.2938 °N -89.4274 °W	Method Code: GPS008
Well Plan Approval #:			SE SE or Govt Lot #: — Section: 36 — Township: 33 N — Range: 8 E	
Address: HORNUNG WELL DRLG LLC N925 CTY HWY W, MERRILL WI 54452		Approval Date (mm-dd-yyyy):		
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.1		

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?

3. Well serves 1 # of CHICKEN FARM
Private,potable — Nontransient
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	32
6	32	200

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 10depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		C		R-RED C-CLAY	Surface	18
K	D	Q		K-BLACK D-DECOMPOSED/WEATHERED Q-GRANITE	18	20
K	H	Q		K-BLACK H-HARD/FIRM Q-GRANITE	20	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	FEMCO 530 6.625 280 WALL WELDED USA 18.9#	Surface	32
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 180 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	32	6 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	9013	03-23-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MH	9067	03-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: PICKED UP WATER BELOW 55'. 15GPM

Created On: 03-10-2026 Updated On: 04-21-2026 Review Status: APPROVED