

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM140		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner WEAVER, ELTON					Phone #		1. Well Location Fire # (if avail.) N4917					
Mailing Address N2224 FRENCH RIDGE RD												
City MERRILL			State WI		Zip Code 54452		Town of RUSSELL Street Address or Road Name and Number N4917 COUNTY LINE RD					
County Lincoln		Co. Permit #		Notification # 10155434701		Completed 03-04-2026		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) HORNUNG, JAMES JR				Lic. # 9013		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.2938 °N -89.4274 °W			Method Code GPS008	
Address HORNUNG WELL DRLG LLC N925 CTY HWY W MERRILL WI 54452				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 36 33 N 8 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #			Common Well #		Specific Capacity 0.1							
3. Well serves 1 # of CHICKEN FARM Private, potable Nontransient Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)			
8 Surface 32			No Rotary - Mud Circulation			No			R C R-RED C-CLAY Surface 18			
6 32 200			Yes Rotary - Air			Yes			K D Q K-BLACK D-DECOMPOSED/WEATHERED Q-GRANITE 18 20			
			No Rotary - Air & Foam			No			K H Q K-BLACK H-HARD/FIRM Q-GRANITE 20 200			
			No Drill-Through Casing Hammer									
			No Reverse Rotary									
			No Cable-tool Bit ___ in. dia...			No						
			No Dual Rotary			No						
			Yes Temp. Outer Casing 10in. dia									
			Yes Removed? 10depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 18 ft. below ground surface		
6		FEMCO 530 6.625 280 WALL WELDED USA 18.9#				Surface		32		11. Well Is 18 in. above grade		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes Disinfected ? Yes Capped ? Yes		
7. Grout or Other Sealing Material												
Method TREMIE PIPE - PUMPED												
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No			
NEAT CEMENT GROUT			Surface		32		6 S		Filled & Sealed Well(s) as needed? No			
13. Constructor / Supervisory Driller Lic # Date Signed JH 9013 03-23-2026 Drill Rig Operator Lic or Reg # Date Signed MH 9067 03-23-2026												

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: PICKED UP WATER BELOW 55'. 15GPM

Created On: 03-10-2026

Updated On: 04-21-2026

Review Status: APPROVED