Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM142

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: VENUS, TROY	Phone #
Mailing Address: 164198 TOWNLINWE RD	
City: WAUSAU	State: WI — Zip Code: 54403
County: Marathon	Co. Permit #: — Notification #: 10168233301 — Completed: 03-10-2026
Well Constructor (Business Name): HORNUNG, JAMES JR	Lic. #: 9013 — Facility ID # (Public Wells):
Address: HORNUNG WELL DRLG LLC N925 CTY HWY W, MERRILL WI 54452	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.3

1. Well Location

Town of WAUSAU	Fire # (if avail.): 164198
Street Address or Road Name and Number: 164198 TOWNLINE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.9469 °N -89.5006 °W	Method Code: GPS008
SW SE or Govt Lot #:	Section: 36 — Township: 29 N — Range: 8 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable Nontransient

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	38

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
N S	N-FINE S-SAND	Surface	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	FEMCO 530 6.625 280 WALL WELDED USA 18.9#	Surface	35
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.5	SS JOHNSON 15 SLOT	35	38

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	38	1 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	9013	03-23-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MH	9067	03-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	55	Septic or Holding, or POWTS Tank	=	56

Comment:

Created On: 03-10-2026 Updated On: 04-21-2026 Review Status: APPROVED