

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM145		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner ANDERSON, JOHN				Phone # (715)874-6789		1. Well Location				Fire # (if avail.)	
Mailing Address 3695 110TH STREET						Village of LAKE HALLIE				3695	
City CHIPPEWA FALLS				State WI		Zip Code 54729				Street Address or Road Name and Number 110TH STREET	
County Chippewa		Co. Permit # 20250151		Notification # 9984381706		Completed 03-10-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) J & K PUMP & WELL SERVICE				Lic. # 8364		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.897 °N -91.4475 °W		Method Code GPS008	
Address 20458 80TH AVE CADOTT WI 54727				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 23 28 N 9 W		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 10		of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?		Construction Type Drilled			
Private, potable				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
6		Surface		96.5		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... T S Y T-TAN/BROWN S-SOFT/LOOSE Y-SAND & GRAVEL	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is	
6		NEW STEEL THREADED AND CUPPLED 20 LBS PER FT ASTM A 53 B 1800 PSI WHEATLAND PIPE				Surface		84		24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
6		JOHNSON STAINLESS STEEL 10 SLOT				83.5		96.5			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
GRANULAR BENTONITE				Surface						2 S	
9. Static Water Level											
71 ft. below ground surface											
10. Pump Test											
Pumping level 72 ft. below surface Pumping at 10 GP M for 12 Hrs. Pumping Method ? Test Pump											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller				Lic #		Date Signed					
JK				6336		04-06-2026					
Drill Rig Operator				Lic or Reg #		Date Signed					
JK				6336		04-06-2026					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	230	Landfill	=	573
Building Drain - Sanitary	=	180	Sewer - Building Sanitary	=	190
			Septic or Holding, or POWTS Tank	=	200

Comment:

Variance ID	Variance or Exception Type	Date	Reason
76561	Landfill Variance	08/19/2025	

Created On: 03-10-2026

Updated On: 04-29-2026

Review Status: APPROVED