

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM146		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner EDWARDS, ANDY						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 4959 CO D						Town of HANSEN											
City VESPER						State WI		Zip Code 54489				Street Address or Road Name and Number 4959 CO D					
County Wood		Co. Permit # w26011		Notification # 10161274901		Completed 03-04-2026		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) BERTRAM JUNEMANN WELL DRILLING INC				Lic. # 84		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.4287 °N -89.9894 °W							
Address 7117 COUNTY ROAD S RUDOLPH WI 54475				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 35 23 N 4 E		Method Code GPS008									
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0				2. Well Type New Well of previous unique well # constructed in					
Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Reason for replaced or reconstructed well ?											
3. Well serves 1 # of FARM Private, potable				Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)		
10 Surface 3			No Rotary - Mud Circulation No								X X-SAND & CLAY		Surface 3				
8.75 3 40			Yes Rotary - Air Yes								N N-SANDSTONE		3 15				
6 40 220			No Rotary - Air & Foam No								H H-SHALE		15 20				
			No Drill-Through Casing Hammer								Q Q-GRANITE		20 220				
			No Reverse Rotary														
			No Cable-tool Bit ___ in. dia... No														
			No Dual Rotary No														
			Yes Temp. Outer Casing 9in. dia														
			Yes Removed? 3depth ft. (If NO explain on back side)														
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		17 ft. below ground surface				16 in. above grade		
6			P.E A-53 .280 NTP-TRI				Surface		40		10. Pump Test				Developed ? Yes		
Dia. (in.)			Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface				Disinfected ? Yes		
											Pumping at 10 GP M for 1 Hrs.				Capped ? Yes		
											Pumping Method ? Test Pump						
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method TREMIE PIPE - PUMPED												Filled & Sealed Well(s) as needed? No					
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement										
NEAT CEMENT GROUT			Surface		40		7 S										
13. Constructor / Supervisory Driller								Lic #		Date Signed							
JJ								6733		04-02-2026							
Drill Rig Operator								Lic or Reg #		Date Signed							
JJ								9350		04-02-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Animal Barn or Barn Pen	>	52
			Septic or Holding, or POWTS Tank	>	50

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture	03/04/2026	< 2 GPM

Created On: 03-10-2026

Updated On: 04-28-2026

Review Status: APPROVED