

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM160		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner RANDALL PLUMLEY					Phone # (920)367-3034		1. Well Location				Fire # (if avail.)		
Mailing Address N10014 NEWTON LAKE RD							Town of STEPHENSON				N10014		
City CRIVITZ					State WI		Zip Code 54114				Street Address or Road Name and Number NEWTON LAKE RD		
County Marinette		Co. Permit #		Notification # 10161991701		Completed 03-06-2026		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) COOPER, GERALD L				Lic. # 6211		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.32267 °N -88.12256 °W				Method Code SCR002	
Address 5050 BROWN RD LITTLE SUAMICO WI 54141				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 22 33 N 19 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 9									
3. Well serves 1 # of NEW HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock					
8		Surface		3		No Rotary - Mud Circulation		No					
6		3		46		No Rotary - Air		No					
						No Rotary - Air & Foam		No					
						No Drill-Through Casing Hammer							
						No Reverse Rotary							
						Yes Cable-tool Bit 8in. dia...		No					
						No Dual Rotary		No					
						No Temp. Outer Casing ___ in. dia							
						No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T	S	S				T-TAN/BROWN S-SOFT/LOOSE S-SAND		Surface		28			
T	S	C				T-TAN/BROWN S-SOFT/LOOSE C-CLAY		28		38			
T	H	S				T-TAN/BROWN H-HARD/FIRM S-SAND		38		46			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STEEL, 18.97 LB PER FT ASTM A53 NTP-TRI WELDED				Surface		43					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
5		SLOTTED STAINLESS STEEL 12 SLOT				43		46					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE		Surface		43		1 S							
9. Static Water Level													
13 ft. below ground surface													
10. Pump Test													
Pumping level 15 ft. below surface Pumping at 18 GP M for 2 Hrs. Pumping Method ? Test Pump													
11. Well Is													
24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
GLC		Lic # 6211		Date Signed 03-11-2026									
Drill Rig Operator		Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Ditch or Culvert	>	50

Comment:

Created On: 03-11-2026

Updated On: 04-08-2026

Review Status: APPROVED