Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM160

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RANDALL PLUMLEY	Phone #: (920)367-3034
Mailing Address: N10014 NEWTON LAKE RD	
City: CRIVITZ	State: WI / Zip Code: 54114
County: Marinette	Co. Permit #:
Notification #: 10161991701	Completed: 03-06-2026
Well Constructor (Business Name): COOPER, GERALD L	Lic. #: 6211
Facility ID # (Public Wells):	
Address: 5050 BROWN RD, LITTLE SUAMICO WI 54141	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 9	

1. Well Location

Town of STEPHENSON	Fire # (if avail.): N10014
Street Address or Road Name and Number: NEWTON LAKE RD	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 45.32267 °N -88.12256 °W	Method Code: SCR002

SW	NW	Section	Township	Range
or Govt Lot #		22	33 N	19 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of NEW HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	3
6	3	46

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 8in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	Surface	28
T	S	C		T-TAN/BROWN S-SOFT/LOOSE C-CLAY	28	38
T	H	S		T-TAN/BROWN H-HARD/FIRM S-SAND	38	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97 LB PER FT ASTM A53 NTP-TRI WELDED	Surface	43
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SLOTTED STAINLESS STEEL 12 SLOT	43	46

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	43	1 S

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 15 ft. below surface

Pumping at 18 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
GLC	6211	03-11-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Ditch or Culvert	>	50

Comment:

Created On: 03-11-2026 Updated On: 04-08-2026 Review Status: APPROVED