Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM180

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: THOMSON JEFFERY			Phone #
Mailing Address: 207 EUCLID AVE.			
City: ARLINGTON HEIGHTS	State: IL	Zip Code: 60004	
County: Door	Co. Permit #:	Notification #: 10167335201	Completed: 03-12-2026

Well Constructor (Business Name): RETZLAFF & GREGORICH	Lic. #: 7267	Facility ID # (Public Wells):	
Address: WELL DRILLING LLC 5861 MARY'S RD NEW FRANKEN WI 54229		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

3. Well serves 1 # of HOME
Private,potable — Borehole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of EGG HARBOR
Fire # (if avail.): 6393
Street Address or Road Name and Number: MONUMENT BLUFF PASS
Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 44.98256 °N -87.3554 °W
Method Code: GPS008

SW SW or Govt Lot # | Section: 16 | Township: 29 N | Range: 26 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	9
8	9	175
6	175	263

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 9depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	S	L		S-SOFT/LOOSE L-LIMESTONE/DOLOMITE	Surface	2
		L		L-LIMESTONE/DOLOMITE	2	263

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	MARUICHI LEAVITT ASTM A53B 6.625IN X 0.280IN PE WELDED JOINT MADE IN USA	Surface	177
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
159 ft. below ground surface

10. Pump Test
Pumping level 220 ft. below surface
Pumping at 30 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT PORTLAND CEMENT	Surface	175	65 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KG	6985	03-12-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Septic or Holding, or POWTS Tank		25

Comment:

Created On: 03-12-2026 Updated On: 04-21-2026 Review Status: APPROVED