

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM188		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MICHELE LUDWIG						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 3841RAINBOW CIR						Town of JACKSON													
City DANBURY						State WI		Zip Code 54830				Street Address or Road Name and Number 3841 RAINBOW CIRCLE							
County Burnett		Co. Permit #		Notification # 10169978201		Completed 04-24-2026		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) MCCULLOUGH AND SONS				Lic. # 44		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.96812 °N -92.18307 °W				Method Code SCR002					
Address 20335 FOREST BLVD N FOREST LAKE MN 55025				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 11 40 N 15 W				2. Well Type New Well									
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ?													
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled											
Private,potable						Hicap Property ? No													
Heat Exchange ___ # of drillholes						Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		66		Yes Rotary - Mud Circulation				No		Y		Y-SAND & GRAVEL		Surface		66	
						No Rotary - Air				No									
						No Rotary - Air & Foam				No									
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...				No									
						No Dual Rotary				No									
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		32 ft. below ground surface				12 in. above grade					
4		SCH 80 SDR21				Surface		62		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 60 ft. below surface				Disinfected ? Yes					
4		JOHNSON 12 SLOT STAINLESS				62		66		Pumping at 10 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ? Airlift									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No							
Method TREMIE PIPE - PUMPED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No									
HIGH SOLIDS GROUT				Surface		58		4 S											
13. Constructor / Supervisory Driller						Lic #		Date Signed											
DM						72		04-24-2026											
Drill Rig Operator						Lic or Reg #		Date Signed											
DAN						7343		04-24-2026											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		110	POWTS dispersal component (soil absorption unit or mound)		130
			Sewer - Building Sanitary		12

Comment:

Created On: 03-12-2026

Updated On: 05-28-2026

Review Status: APPROVED