Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM229

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WRIGHT, NICK	Phone #
Mailing Address: 4780 CHURCH RD	
City: CONOVER	State: WI — Zip Code: 54519
County: Vilas	Co. Permit #: — Notification #: 10169570701 — Completed: 03-12-2026

1. Well Location

Town of CONOVER

Fire # (if avail.): 4780

Street Address or Road Name and Number: CHURCH RD

Subdivision Name: — Lot #: — Block #: —

Well Constructor (Business Name): HEDBERG W D/ECS HOLDINGS LLC	Lic. #: 6416 — Facility ID # (Public Wells):
Address: PO BOX 1206 EAGLE RIVER WI 54521	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 2.1	

Latitude / Longitude in Decimal Degree (DD): 46.02616 °N -89.25418 °W — Method Code: GPS008

SE	SW	Section	Township	Range
or Govt Lot #		16	41 N	10 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

REPLACE 4" WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	99

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	Surface	75
T	N	Y		T-TAN/BROWN N-FINE Y-SAND & GRAVEL	75	90
T	A	S		T-TAN/BROWN A-COARSE S-SAND	90	99

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NOVATUBE ASTM A53B 18.97# WELDED	Surface	96
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SS BIGFOOT 10 SLOT	96	99

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	52	1.5 S

9. Static Water Level

63 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
ES	6673	03-12-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 03-17-2026 Updated On: 04-09-2026 Review Status: APPROVED