

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM229		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner WRIGHT, NICK						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 4780 CHURCH RD						Town of CONOVER						4780									
City CONOVER						State WI		Zip Code 54519				Street Address or Road Name and Number CHURCH RD									
County Vilas		Co. Permit #		Notification # 10169570701		Completed 03-12-2026		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) HEDBERG W D/ECS HOLDINGS LLC				Lic. # 6416		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.02616 °N -89.25418 °W				Method Code GPS008							
Address PO BOX 1206 EAGLE RIVER WI 54521				Well Plan Approval #				SE		SW		Section 16		Township 41 N		Range 10 E					
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 2.1				2. Well Type Replacement				of previous unique well #		constructed in					
Reason for replaced or reconstructed well ? REPLACE 4" WELL																					
3. Well serves 1 # of HOME				Hicap Well ? No				Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ? No				Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		99		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>Yes</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)						T		Y		T-TAN/BROWN Y-SAND & GRAVEL		Surface		75	
										T		N Y		T-TAN/BROWN N-FINE Y-SAND & GRAVEL		75		90			
										T		A S		T-TAN/BROWN A-COARSE S-SAND		90		99			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		63 ft. below ground surface				16 in. above grade							
6		NOVATUBE ASTM A53B 18.97# WELDED				Surface		96		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 70 ft. below surface				Disinfected ? Yes							
6		SS BIGFOOT 10 SLOT				96		99		Pumping at 15 GP M for 1 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material														Pumping Method ? Test Pump							
Method		MOUNDED												12. Notified Owner of need to fill & seal ? Yes							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement								Filled & Sealed Well(s) as needed? Yes							
GRANULAR BENTONITE		Surface		52		1.5 S															
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														ES				6673		03-12-2026	
														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 03-17-2026

Updated On: 04-09-2026

Review Status: APPROVED