

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM234		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner SLEMENSKY JOE					Phone #		1. Well Location Village of SALEM LAKES Street Address or Road Name and Number 240TH AVE				Fire # (if avail.) 6041	
Mailing Address 6041 240TH AVE												
City PADDOCK LAKE			State WI	Zip Code 53168								
County Kenosha	Co. Permit #	Notification # 10167436401		Completed 03-09-2026		Subdivision Name			Lot #	Block #		
Well Constructor (Business Name) GOHLKE WELL DRILLING LLC			Lic. # 6642	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.58158 °N -88.09983 °W			Method Code GPS008			
Address 5338 STATE RD 50 BURLINGTON WI 53105			Well Plan Approval #		NW	NE	Section 2	Township 1 N	Range 20 E			
			Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 1.2		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? 5" WELL NOT PRODUCING						
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled						
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock					
9	Surface	58	Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology												
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
G		Z	C	Y		Z-CLAY & GRAVEL	Surface	4				
						G-GRAY C-CLAY	4	52				
						Y-SAND & GRAVEL	52	58				
6. Casing, Liner, Screen												
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)							
5	NEW PVC CERTAINTED 1120 SDR 21 PWD2241			Surface	53							
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)							
5	5'X5" PVC .10 SLOT TITAN HYFLOW			53	58							
7. Grout or Other Sealing Material												
Method TREMIE PIPE - PUMPED												
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement								
GROUT WELL DF		Surface	53	5								
9. Static Water Level 30 ft. below ground surface												
10. Pump Test Pumping level 40 ft. below surface Pumping at 12 GP M for 1 Hrs. Pumping Method ? Test Pump												
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes												
12. Notified Owner of need to fill & seal ? No												
Filled & Sealed Well(s) as needed? Yes GOHLKE DONE												
13. Constructor / Supervisory Driller				Lic #		Date Signed						
TLS				6643		03-18-2026						
Drill Rig Operator				Lic or Reg #		Date Signed						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Collector - Sanitary		100

Comment:

Created On: 03-18-2026

Updated On: 04-10-2026

Review Status: APPROVED