Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM234

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SLEMENSKY JOE	Phone #
Mailing Address: 6041 240TH AVE	
City: PADDOCK LAKE	State: WI — Zip Code: 53168
County: Kenosha	Co. Permit #: — Notification #: 10167436401 — Completed: 03-09-2026

1. Well Location

Village of SALEM LAKES	Fire # (if avail.): 6041
Street Address or Road Name and Number: 240TH AVE	
Subdivision Name: — Lot #: — Block #: —	

Well Constructor (Business Name): GOHLKE WELL DRILLING LLC	Lic. #: 6642	Facility ID # (Public Wells):	
Address: 5338 STATE RD 50 BURLINGTON WI 53105		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.2	

Latitude / Longitude in Decimal Degree (DD): 42.58158 °N -88.09983 °W				Method Code: GPS008
NW NE or Govt Lot #:	Section: 2	Township: 1 N	Range: 20 E	

2. Well Type Replacement
of previous unique well # — constructed in —
Reason for replaced or reconstructed well ?: 5" WELL NOT PRODUCING
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	58

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Z		Z-CLAY & GRAVEL	Surface	4
G		C		G-GRAY C-CLAY	4	52
		Y		Y-SAND & GRAVEL	52	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NEW PVC CERTAINTEED 1120 SDR 21 PWD2241	Surface	53
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	5'X5" PVC .10 SLOT TITAN HYFLOW	53	58

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GROUT WELL DF	Surface	53	5

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 12 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes
GOHLKE DONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLS	6643	03-18-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Collector - Sanitary		100

Comment:

Created On: 03-18-2026 Updated On: 04-10-2026 Review Status: APPROVED