

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM236		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner ALANEN PAM					Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 4818 330TH AVE							Town of WHEATLAND					
City BURLINGTON					State WI		Zip Code 53105		Street Address or Road Name and Number 4818 330TH AVE			
County Kenosha		Co. Permit #		Notification # 10170050001		Completed 03-12-2026		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) GOHLKE WELL DRILLING LLC				Lic. # 6642		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.59352 °N -88.20949 °W			Method Code GPS008	
Address 5338 STATE RD 50 BURLINGTON WI 53105				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 35 2 N 19 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? POINT WELL DRY				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #		Common Well #		Specific Capacity 1.2								
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No				Construction Type Drilled				
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		
9		Surface		42		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) Y C Y-YELLOW C-CLAY Surface 10 G C G-GRAY C-CLAY 10 35 Y Y-SAND & GRAVEL 35 42		
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		
5		NEW PVC CERTAINTED 1120 SDR 21 PWD2241				Surface		37		10 ft. below ground surface 10. Pump Test		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is		
5		5'X5" PVC .10 SLOT TITAN HYFLOW				37		42		12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes		
7. Grout or Other Sealing Material												
Method TREMIE PIPE - PUMPED												
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No				
GROUT WELL DF		Surface		37		4		Filled & Sealed Well(s) as needed? Yes GOHLKE DONE				
13. Constructor / Supervisory Driller												
TLS		6643		03-18-2026		Lic #		Date Signed				
Drill Rig Operator		JRR		9534		03-18-2026		Lic or Reg #		Date Signed		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Building Sanitary		100

Comment:

Created On: 03-18-2026

Updated On: 04-10-2026

Review Status: APPROVED