Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM242

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RICHARD AND NICOLE DUBOIS TRUST	Phone #: (715)213-2323
Mailing Address: 3401 FREY COURT, LOT 10	
City: MARSHFIELD	State: WI — Zip Code: 54449
County: Vilas	Co. Permit #:
Notification #: 10162630501	Completed: 03-12-2026
Well Constructor (Business Name): BRUNNER WELL DRILLING LLC	Lic. #: 6469
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 303 S 8TH ST MEDFORD WI 54451	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.7	

1. Well Location

Town of ARBOR VITAE

Fire # (if avail.):

Street Address or Road Name and Number: JUST NORTH OF 1412 ARBOR VITAE LANE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 45.9188 °N -89.6889 °W

Method Code: GPS008

NE	SW	Section	Township	Range
or Govt Lot #		25	40 N	6 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

QUANTITY

Construction Type: Drilled

3. Well serves 8 # of MOBILE HOMES

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	72

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	E	S		T-TAN/BROWN E-CLEAN S-SAND	Surface	16
T		M		T-TAN/BROWN M-SILT	16	25
T	M	S		T-TAN/BROWN M-MEDIUM S-SAND	25	45
T	N	S		T-TAN/BROWN N-FINE S-SAND	45	72

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL, P.E., A53B, 18.97#/FT., WHEATLAND, .280 WALL, WELDED JOINTS	Surface	66
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.5	S.S. #15 AND #12 , #15 ON TOP	66	72

9. Static Water Level

26.5 ft. below ground surface

10. Pump Test

Pumping level 57 ft. below surface

Pumping at 20 GP M for 8 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED WHILE DRIVING

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? No

TO BE DONE AFTER NEW WELL IS HOOKED UP.

13. Constructor / Supervisory Driller	Lic #	Date Signed
JWB	4379	03-18-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	90	Sewer - Building Sanitary	>	40
			Septic or Holding, or POWTS Tank	>	75

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time		WE ARE THE PUMP INSTALLER AND SAMPLE WILL BE TAKEN AFTER PUMP IS INSTALLED AND SYSTEM IS UP AND RUNNING.

Created On: 03-18-2026 Updated On: 04-13-2026 Review Status: APPROVED