

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM254		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner RICHARD AND NICOLE DUBOIS TRUST						Phone # (715)213-2323		1. Well Location				Fire # (if avail.)			
Mailing Address 3401 FREY COURT, LOT 10								Town of MINOCQUA							
City MARSHFIELD						State WI		Zip Code 54449							
County Oneida		Co. Permit #		Notification # 10156350101		Completed 03-12-2026		Subdivision Name ROCKWOOD ESTATES				Lot # 27		Block # 1	
Well Constructor (Business Name) BRUNNER WELL DRILLING LLC				Lic. # 6469		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.8982 °N -89.805 °W				Method Code GPS008	
Address 303 S 8TH ST MEDFORD WI 54451				Well Plan Approval #		NE NE		Section 1		Township 39 N		Range 5 E		or Govt Lot #	
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 1.5						2. Well Type New Well					
3. Well serves 1 # of NEW HOME						Hicap Well ? No		of previous unique well #				constructed in			
Private, potable						Hicap Property ? No						Reason for replaced or reconstructed well ?			
Heat Exchange ___ # of drillholes						Hicap Potable ? No						Construction Type Drilled			
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		59		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
T C M		T-TAN/BROWN C-CLAY M-SILTY		Surface		4									
T E S		T-TAN/BROWN E-CLEAN S-SAND		4		15									
T Y U		T-TAN/BROWN Y-SAND & GRAVEL U-MUDDY OR MURKY		15		30									
T C G		T-TAN/BROWN C-CLAY G-W/GRAVEL/STONES		30		50									
T E Y		T-TAN/BROWN E-CLEAN Y-SAND & GRAVEL		50		59									
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW BLACK STEEL, P.E., A53B, 18.97#/FT., WHEATLAND, .280 WALL, WELDED JOINTS				Surface		56							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
5.5		S.S.#12				56		59							
7. Grout or Other Sealing Material															
Method MOUNDED WHILE DRIVING															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface				2 S							
9. Static Water Level															
17 ft. below ground surface															
10. Pump Test															
Pumping level 27 ft. below surface															
Pumping at 15 GP M for 1 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
50 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
JWB				Lic # 4379		Date Signed 03-19-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time		WE ARE THE PUMP INSTALLER AND SAMPLE WILL BE TAKEN AFTER PUMP IS INSTALLED AND SYSTEM IS UP AND RUNNING.

Created On: 03-19-2026

Updated On: 04-13-2026

Review Status: APPROVED