Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: ACM254

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RICHARD AND NICOLE DUBOIS TRUST	Phone #: (715)213-2323
Mailing Address: 3401 FREY COURT, LOT 10	
City: MARSHFIELD	State: WI / Zip Code: 54449

County	Co. Permit #	Notification #	Completed
Oneida		10156350101	03-12-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
BRUNNER WELL DRILLING LLC	6469	

Address: 303 S 8TH ST, MEDFORD WI 54451

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #:

Common Well #:

Specific Capacity: 1.5

1. Well Location

Town of MINOCQUA

Fire # (if avail.):

Street Address or Road Name and Number: 11027 ROCKWOOD DR.

Subdivision Name	Lot #	Block #
ROCKWOOD ESTATES	27	1

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.8982 °N -89.805 °W	GPS008

NE NE or Govt Lot #	Section	Township	Range
	1	39 N	5 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of NEW HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	59

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		C	M	T-TAN/BROWN C-CLAY M-SILTY	Surface	4
T	E	S		T-TAN/BROWN E-CLEAN S-SAND	4	15
T		Y	U	T-TAN/BROWN Y-SAND & GRAVEL U-MUDDY OR MURKY	15	30
T		C	G	T-TAN/BROWN C-CLAY G-W/GRAVEL/STONES	30	50
T	E	Y		T-TAN/BROWN E-CLEAN Y-SAND & GRAVEL	50	59

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL, P.E., A53B, 18.97#/FT., WHEATLAND, .280 WALL, WELDED JOINTS	Surface	56
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.5	S.S.#12	56	59

7. Grout or Other Sealing Material

Method: MOUNDED WHILE DRIVING

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level

17 ft. below ground surface

10. Pump Test

Pumping level 27 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

50 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JWB	4379	03-19-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time		WE ARE THE PUMP INSTALLER AND SAMPLE WILL BE TAKEN AFTER PUMP IS INSTALLED AND SYSTEM IS UP AND RUNNING.

Created On: 03-19-2026 Updated On: 04-13-2026 Review Status: APPROVED