

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM263		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner DAVE RUTZ						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N7180 5TH AVE						Town of PLAINFIELD						N7180			
City PLAINFIELD						State WI		Zip Code 54966				Street Address or Road Name and Number N7180 5TH AVE			
County Waushara		Co. Permit #		Notification # 10162490101		Completed 03-05-2026		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) LOEHRKE, NEAL D				Lic. # 133		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.23876 °N -89.52234 °W				Method Code SCR002	
Address VALLEY WELL DRILLING N1600 HWY 10 S WEYAUWEGA WI 54983				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 2 20 N 8 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? UPDATE BASEMENT POINT Construction Type Drilled							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 7.5											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		63		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary Yes Cable-tool Bit 6in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
Q S		Q-CAVING S-SAND				Surface		63							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL 18.97 LBS/FT A53B WHEATLAND WELDED				Surface		59							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		TELESCOPE STAINLESS STEEL 20 SLOT				59		63							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE		Surface		15		2 S									
9. Static Water Level															
15 ft. below ground surface															
10. Pump Test															
Pumping level 17 ft. below surface Pumping at 15 GP M for 30 Hrs. Pumping Method ? Test Pump															
11. Well Is															
24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes ORIGINAL POINT WAS NOT CONTRACTED FOR ABANDONMENT, PER OWNER Filled & Sealed Well(s) as needed? Yes 3/19/2026 PULLED ONE NEW 23' DEEP 1.25 POINT FOR SALVAGE, FILLED HOLE WITH PEL PLUG 1/4" TR30															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
NDL				133		03-05-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									
NDL				133		03-05-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	50	POWTS dispersal component (soil absorption unit or mound)	>	60

Comment:

Created On: 03-19-2026

Updated On: 04-13-2026

Review Status: APPROVED