

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	50	POWTS dispersal component (soil absorption unit or mound)	>	100

Comment: 2ND WELL ON PROPERTY FOR DRINKING WATER
1ST WELL IS BEING USED FOR SPRINKLER WELL

Created On: 03-20-2026

Updated On: 04-23-2026

Review Status: APPROVED