Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM285

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SIMMONS, BENJAMIN			Phone #
Mailing Address: 3742 33RD ST			
City: ELK MOUND	State: WI	Zip Code: 54739	
County: Chippewa	Co. Permit #: 20260026	Notification #: 10169327601	Completed: 03-23-2026

1. Well Location

Fire # (if avail.): 3742

Town of WHEATON

Street Address or Road Name and Number: 33RD ST

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): MIDWEST WELL DRILLING & HYDROFRACKING LLC

Lic. #: 6799

Facility ID # (Public Wells)

Latitude / Longitude in Decimal Degree (DD): 44.8964 °N -91.6036 °W

Method Code: GPS008

Well Plan Approval #

SE NW or Govt Lot #: | Section: 21 | Township: 28 N | Range: 10 W

Address: 31569 150TH AV
CORNELL WI 54732-6100

Approval Date (mm-dd-yyyy)

2. Well Type Replacement

of previous unique well # | constructed in

Hicap Permanent Well # | Common Well # | Specific Capacity: 0.9

Reason for replaced or reconstructed well ?: LOW YIELD

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	80
6	80	180

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	32
Y	H	N		Y-YELLOW H-HARD/FIRM N-SANDSTONE	32	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL 18.97#FT A53B HUSTEEL PE WELDED	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

96 ft. below ground surface

10. Pump Test

Pumping level 112 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: PRESSURE GROUT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	80	24 S

12. Notified Owner of need to fill & seal ? Yes

DONE

Filled & Sealed Well(s) as needed? Yes

DONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
MSP	8236	04-23-2026
Drill Rig Operator	Lic or Reg #	Date Signed
MSP		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		109	Septic or Holding, or POWTS Tank		99

Comment:

Created On: 03-23-2026 Updated On: 10-15-2026 Review Status: APPROVED