Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM294

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FROLIK, DONALD	Phone #
Mailing Address: 2706 21ST ST	
City: RICE LAKE	State: WI — Zip Code: 54868
County: Barron	Co. Permit #: — Notification #: 10198500201 — Completed: 03-25-2026
Well Constructor (Business Name): MIDWEST WELL DRILLING & HYDROFRACKING LLC	Lic. #: 6799 — Facility ID # (Public Wells):
Address: 31569 150TH AV, CORNELL WI 54732-6100	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #:	Specific Capacity: 3

1. Well Location

Town of OAK GROVE	Fire # (if avail.): 2706
Street Address or Road Name and Number: 21ST ST	
Subdivision Name: — Lot #: — Block #:	
Latitude / Longitude in Decimal Degree (DD): 45.5963 °N -91.7242 °W	Method Code: GPS008
SE SE or Govt Lot #: — Section: 16 — Township: 36 N — Range: 11 W	

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: PUMP STUCK

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	120

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	50
I	V	Z		I-WHITE V-NON-CAVING Z-CLAY & GRAVEL	50	97
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	97	114
I	M	N		I-WHITE M-MEDIUM N-SANDSTONE	114	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL 18.97#FT A53B HUSTEEL PE WELDED	Surface	100
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

42 ft. below ground surface

10. Pump Test

Pumping level 46 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		3 S

12. Notified Owner of need to fill & seal ? Yes

DONE

Filled & Sealed Well(s) as needed? Yes

DONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
MSP	8236	04-27-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MSP		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		113	Septic or Holding, or POWTS Tank		101

Comment:

Created On: 03-24-2026 Updated On: 10-15-2026 Review Status: APPROVED