Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM295

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PETERSON, JOHN	Phone #
Mailing Address: 1675 11 1/2 ST	
City: BARRON	State: WI — Zip Code: 54812
County: Barron	Co. Permit #: — Notification #: 10198496501 — Completed: 03-24-2026
Well Constructor (Business Name): MIDWEST WELL DRILLING & HYDROFRACKING LLC	Lic. #: 6799 — Facility ID # (Public Wells):
Address: 31569 150TH AV CORNELL WI 54732-6100	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.3

1. Well Location

Town of CLINTON	Fire # (if avail.): 1675
Street Address or Road Name and Number: 11 1/2 ST	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.4482 °N -91.9102 °W	Method Code: GPS008
SE NE or Govt Lot #: — Section: 12 — Township: 34 N — Range: 13 W	

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: LOW YIELD

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	120

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	C		T-TAN/BROWN V-NON-CAVING C-CLAY	Surface	10
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	10	52
T	V	P		T-TAN/BROWN V-NON-CAVING P-HARDPAN	52	104
Y	H	N		Y-YELLOW H-HARD/FIRM N-SANDSTONE	104	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL 18.97#FT A53B HUSTEEL PE WELDED	Surface	106
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

27 ft. below ground surface

10. Pump Test

Pumping level 36 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

12. Notified Owner of need to fill & seal ? Yes

DONE

Filled & Sealed Well(s) as needed? Yes

DONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
MSP	8236	04-24-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MSP		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		97	Septic or Holding, or POWTS Tank		95

Comment:

Created On: 03-24-2026 Updated On: 10-15-2026 Review Status: APPROVED