

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM295		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner PETERSON, JOHN					Phone #		1. Well Location Fire # (if avail.) 1675				
Mailing Address 1675 11 1/2 ST											
City BARRON			State WI		Zip Code 54812		Town of CLINTON				
Street Address or Road Name and Number					11 1/2 ST						
County Barron		Co. Permit #		Notification # 10198496501		Completed 03-24-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name)				Lic. # 6799		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)		Method Code	
MIDWEST WELL DRILLING & HYDROFRACKING LLC						Well Plan Approval #		45.4482 °N -91.9102 °W		GPS008	
Address 31569 150TH AV CORNELL WI 54732-6100				Approval Date (mm-dd-yyyy)		SE NE Section Township Range		or Govt Lot # 12 34 N 13 W			
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? LOW YIELD Construction Type Drilled					
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock		8. Geology		
6	Surface	120	No Rotary - Mud Circulation No Yes Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) T V C T-TAN/BROWN V-NON-CAVING C-CLAY Surface 10 T Q S T-TAN/BROWN Q-CAVING S-SAND 10 52 T V P T-TAN/BROWN V-NON-CAVING P-HARDPAN 52 104 Y H N Y-YELLOW H-HARD/FIRM N-SANDSTONE 104 120		
6. Casing, Liner, Screen											
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)	9. Static Water Level			11. Well Is		
6	NEW STEEL 18.97#FT A53B HUSTEEL PE WELDED			Surface	106	27 ft. below ground surface			24 in. above grade		
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)	10. Pump Test			Developed ? Yes Disinfected ? Yes Capped ? Yes		
						Pumping level 36 ft. below surface Pumping at 12 GP M for 1 Hrs. Pumping Method ? Test Pump					
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ? Yes DONE Filled & Sealed Well(s) as needed? Yes DONE					
Method MOUNDED											
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement		13. Constructor / Supervisory Driller Lic # Date Signed					
GRANULAR BENTONITE		Surface		2 S		MSP 8236 04-24-2026 Drill Rig Operator Lic or Reg # Date Signed MSP					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		97	Septic or Holding, or POWTS Tank		95

Comment:

Created On: 03-24-2026

Updated On: 05-18-2026

Review Status: APPROVED