Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM297

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NIGBUR TERRI	Phone #
Mailing Address: 5707 ST GERMAIN RD	
City: ST GERMAIN	State: WI — Zip Code: 54560
County: Oneida	Co. Permit #: — Notification #: 10198668701 — Completed: 03-24-2026
Well Constructor (Business Name): JELINEK WELL DRILLING INC	Lic. #: 6041 — Facility ID # (Public Wells):
Address: 3480 HWY N, RHINELANDER WI 54501	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.5

1. Well Location

Town of NEWBOLD				Fire # (if avail.): 5707
Street Address or Road Name and Number: ST GERMAIN RD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 45.8915 °N -89.4389 °W				Method Code: GPS008
SE SW or Govt Lot #:	Section: 1	Township: 39 N	Range: 8 E	

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: FAILING POINT

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	54

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	A	Y		T-TAN/BROWN A-COARSE Y-SAND & GRAVEL	Surface	34
T	N	X		T-TAN/BROWN N-FINE X-SAND & CLAY	34	40
T	A	S		T-TAN/BROWN A-COARSE S-SAND	40	54

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B 18.97 #/FT WELDED	Surface	51
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	JOHNSON 3'10 SLOT SS	51	54

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	35	2 S

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

14 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
CG	8207	03-24-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CG	8207	03-24-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		45	POWTS dispersal component (soil absorption unit or mound)		55

Comment:

Created On: 03-24-2026 Updated On: 10-15-2026 Review Status: APPROVED