

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM298		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner S&M DEVELOPMENT LLC				Phone # (715)281-8810		1. Well Location				Fire # (if avail.)	
Mailing Address N2355 SKYVIEW LANE						Town of DAYTON				N2335	
City WAUPACA				State WI		Zip Code 54981				Street Address or Road Name and Number N2335 SKY VIEW LANE	
County Waupaca		Co. Permit #		Notification # 10046933501		Completed 03-23-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) VETTER, WILLIAM				Lic. # 6351		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.3239 °N -89.11245 °W		Method Code SCR002	
Address 1036 TOWNSEND RD WAUPACA WI 54981				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 1 21 N 11 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 0		of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?		Construction Type Drilled			
Private, potable				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
6		Surface		123		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary Yes Cable-tool Bit 6in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) T Q Y T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL Surface 31 T S C T-TAN/BROWN S-SOFT/LOOSE C-CLAY 31 60 G H P G-GRAY H-HARD/FIRM P-HARDPAN 60 114 T W S T-TAN/BROWN W-WATER BEARING S-SAND 114 123	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level	
6		STEEL WELDED JOINT WHEATLAND 18.97PDS PER FT 6.625X280A53GRB				Surface		119		37 ft. below ground surface	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is	
6		SS. 10 SLOT JOHNSON				119		123		18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No			
GRANULAR BENTONITE		Surface		12		4 S		Filled & Sealed Well(s) as needed? No			
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
WV		6351		03-24-2026							
Drill Rig Operator		Lic or Reg #		Date Signed							
GV		8784		03-24-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		100	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 03-24-2026

Updated On: 04-14-2026

Review Status: APPROVED