Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM298

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: S&M DEVELOPMENT LLC	Phone #: (715)281-8810
Mailing Address: N2355 SKYVIEW LANE	
City: WAUPACA	State: WI — Zip Code: 54981
County: Waupaca	Co. Permit #:
Notification #: 10046933501	Completed: 03-23-2026
Well Constructor (Business Name): VETTER, WILLIAM	Lic. #: 6351
Facility ID # (Public Wells):	
Address: 1036 TOWNSEND RD WAUPACA WI 54981	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.5	

1. Well Location

Town of DAYTON	Fire # (if avail.): N2335
Street Address or Road Name and Number: N2335 SKY VIEW LANE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.3239 °N -89.11245 °W	Method Code: SCR002
SW NE or Govt Lot #:	Section: 1 — Township: 21 N — Range: 11 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	123

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	31
T	S	C		T-TAN/BROWN S-SOFT/LOOSE C-CLAY	31	60
G	H	P		G-GRAY H-HARD/FIRM P-HARDPAN	60	114
T	W	S		T-TAN/BROWN W-WATER BEARING S-SAND	114	123

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL WELDED JOINT WHEATLAND 18.97PDS PER FT 6.625X280A53GRB	Surface	119
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SS. 10 SLOT JOHNSON	119	123

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	12	4 S

9. Static Water Level

37 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WV	6351	03-24-2026
Drill Rig Operator	Lic or Reg #	Date Signed
GV	8784	03-24-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		100	POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 03-24-2026 Updated On: 10-15-2026 Review Status: APPROVED