Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM299

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MIKE HEIN			Phone #
Mailing Address: N1586 S BRANCH PATH			
City: KESHENA	State: WI	Zip Code: 54135	
County: Menominee	Co. Permit #:	Notification #: 10190346201	Completed: 03-20-2026

Well Constructor (Business Name): ROCK SOLID WELL DRILLING LLC	Lic. #: 9321	Facility ID # (Public Wells):	
Address: 531 STATE HIGHWAY 73 NEKOOSA WI 54457		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 16.5	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of MENOMINEE

Fire # (if avail.): N1586

Street Address or Road Name and Number: S BRANCH PATH

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 44.9095 °N -88.5654 °W
Method Code: SCR002

SW NW or Govt Lot #: | Section: 16 | Township: 28 N | Range: 16 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
CHANGE OF WELL LOCATION DUE TO ADDING ON TO HOUSE

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	46

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
M S	M-MEDIUM S-SAND	Surface	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	F480 PVC, SDR 21, 200PSI, CRESLINE, GLUED	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	S. S. #12	40	46

7. Grout or Other Sealing Material
Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
20% SOLID PUMPABLE BENT	Surface	38	7 S
SAND PACK	38	40	2 S
RED FLINT GRAVEL PACK #30	40	46	4 S

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 12 ft. below surface
Pumping at 33 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JP	9099	04-05-2026
Drill Rig Operator	Lic or Reg #	Date Signed
JP	9099	04-05-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		46

Comment:

Created On: 03-24-2026 Updated On: 10-15-2026 Review Status: APPROVED