

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM299		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner MIKE HEIN					Phone #		1. Well Location Fire # (if avail.) Town of MENOMINEE N1586 Street Address or Road Name and Number S BRANCH PATH							
Mailing Address N1586 S BRANCH PATH														
City KESHENA			State WI	Zip Code 54135		Subdivision Name Lot # Block #								
County Menominee	Co. Permit #	Notification # 10190346201		Completed 03-20-2026										
Well Constructor (Business Name) ROCK SOLID WELL DRILLING LLC			Lic. # 9321	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.9095 °N -88.5654 °W			Method Code SCR002					
Address 531 STATE HIGHWAY 73 NEKOOSA WI 54457			Well Plan Approval #		SW NW	Section 16	Township 28 N	Range 16 E						
			Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? CHANGE OF WELL LOCATION DUE TO ADDING ON TO HOUSE Construction Type Drilled								
3. Well serves 1 # of HOME				Hicap Well ? No										
Private, potable				Hicap Property ? No										
Heat Exchange ___ # of drillholes				Hicap Potable ? No										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)	
9	Surface	46	Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						M	S	M-MEDIUM S-SAND	Surface	46	
6. Casing, Liner, Screen											8. Geology			
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)	9. Static Water Level 10 ft. below ground surface			11. Well Is 14 in. above grade					
5	F480 PVC, SDR 21, 200PSI, CRESLINE, GLUED			Surface	40	10. Pump Test Pumping level 12 ft. below surface Pumping at 33 GP M for 1 Hrs. Pumping Method ? Test Pump			Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)									
5	S. S. #12			40	46									
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED											12. Notified Owner of need to fill & seal ? Yes			
Kind of Sealing Material			From (ft.)	To (ft.)	# Sacks Cement		Filled & Sealed Well(s) as needed? Yes							
20% SOLID PUMPABLE BENT			Surface	38	7 S									
SAND PACK			38	40	2 S									
RED FLINT GRAVEL PACK #30			40	46	4 S									
											13. Constructor / Supervisory Driller		Lic #	Date Signed
											JP	9099	04-05-2026	
											Drill Rig Operator		Lic or Reg #	Date Signed
											JP	9099	04-05-2026	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		46

Comment:

Created On: 03-24-2026

Updated On: 04-29-2026

Review Status: APPROVED