

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM305		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner MILLER, JONAS J-LINE WOODCRAFT				Phone # (608)269-1409		1. Well Location				Fire # (if avail.)	
Mailing Address W102 STATE RD 16						Town of BURNS				W106	
City SPARTA				State WI		Zip Code 54656				Street Address or Road Name and Number STATE RD 16	
County La Crosse		Co. Permit # 2026-026		Notification # 10199971801		Completed 03-25-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) OIUM, KELLY WELL DRILLING INC				Lic. # 8217		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.92817 °N -90.91353 °W		Method Code GPS008	
Address N50021 MISSELL ROAD STRUM WI 54770				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 25 17 N 5 W		2. Well Type Replacement			
Hicap Permanent Well #				Common Well #		Specific Capacity 4.6		Reason for replaced or reconstructed well ? LACK OF WATER			
3. Well serves 1 # of HOME Private,potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
6		Surface		60		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary Yes Cable-tool Bit 6in. dia... No No Dual Rotary Yes No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
T	N	S	T-TAN/BROWN N-FINE S-SAND				Surface		3		
T	A	S	T-TAN/BROWN A-COARSE S-SAND				3		40		
T	A	Y	T-TAN/BROWN A-COARSE Y-SAND & GRAVEL				40		60		
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		VICTOR PIPE & STEEL 6.620XA53B.280 EWTC				Surface		57			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
6		10 SLOT JOHNSON STAINLESS STEEL SCREEN				57		60			
9. Static Water Level											
25 ft. below ground surface											
10. Pump Test											
Pumping level 30 ft. below surface Pumping at 23 GP M for 2 Hrs. Pumping Method ? Test Pump											
11. Well Is											
24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes											
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE		Surface		57		3 S					
12. Notified Owner of need to fill & seal ? No OWNER IS KEEPING EXISTING Filled & Sealed Well(s) as needed? No OWNER IS KEEPING EXISTING											
13. Constructor / Supervisory Driller				Lic #		Date Signed					
KO				6244		04-13-2026					
Drill Rig Operator				Lic or Reg #		Date Signed					
JG				8980		04-13-2026					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		36	Animal Barn or Barn Pen		59

Comment:

Created On: 03-25-2026

Updated On: 05-06-2026

Review Status: APPROVED